



KHULNA SHIPYARD LIMITED

BANGLADESH NAVY, KHULNA

PHONE : 02-477720003

E-mail : oiocomf.ksy@gmail.com

BABE (F)–123/RI&RS/2024-25

24 July 2024

Dear Sir

INVITATION FOR QUOTATION OF RUBBER INSULATED & RUBBER SHEATHED FLEXIBLE ELECTRIC CABLE - 4X95MM.

1. Khulna Shipyard Limited (KSY) will procure “Rubber Insulated & Rubber sheathed Flexible Electric Cable - 4X95mm” as per attach specification (01 Page), following terms & condition:
2. Submission of quotation as local supply terms:
 - a) Please send your offer delivery at KSY site basis. Offer should include supply of materials including custom duty, local vat & tax etc. within 29/07/2024 (1500 Hours) by e-mail or closed envelop.
 - b) Payment: 100% payment will be made after receiving the material at KSY and satisfactory acceptance after deducting of VAT and TAX.
 - c) Delivery: 45 days from the Purchase Order.
3. 03% (Three) Bid Bond/Earnest Money of the total quoted value must be submit with offer. Bid Bond may be Pay Order/Bank Guarantee in favour of Khulna Shipyard Limited, Khulna.
4. 05% Performance Guarantee (PG) is to be submitted before Purchase Order.
5. Certificate: Supplier must provide manufacturer certificate as regard to the genuinity of the source and items.
6. Offer Validity: 45 Days from Tender Opening Date.

N.B: Invitation for Quotation (IFQ) for this item had already been published on 09 July 2024 & Opening date was mentioned as 22 July 2024 which was already over due to an unavoidable situation—so considering the above against the previous IFQ.

Yours sincerely

Sk. Shah Moshir Rahman
Manager Admin
For Managing Director

**ITEM SPECIFICATIONS OF RUBBER INSULATED & RUBBER SHEATHED
FLEXIBLE ELECTRIC CABLE - 4X95MM**

Purpose:	For power supply through reel moving type to the berth crane
Demand Quantity	160.0 Meter
Country Origin	Italy/ EU countries/ China (To be mentioned.)
Country Manufacture	Italy/ EU countries/ China (To be mentioned.)
Manufacturing Year	2023 or later.
Brand	Eland cable or equivalent
Size	4 X 95 mm ²
Weight	To be mentioned.
Type:	H07RN-F Neoprene crane cable
Nominal Cross Section Area Of Conductor:	4 X 95 mm ²
Flexibility:	Class 5 (Minimum)
Number Of Strand:	To be mentioned.
Thickness Of Each Strand:	To be mentioned.
Voltage Rating:	600/ 1000 Volt AC
Insulation:	EPR (Ethylene Propylene Rubber)
Outer Sheath:	PCP (Polychloroprene)
Nominal Thickness Of Insulation:	To be mentioned.
Nominal Thickness Of Sheath:	To be mentioned.
Current Rating:	Min. 225 Amps (At operating temperature 35 ° C)
Conductor:	100% Flexible stranded copper or to be Mentioned
Outer Sheath Color:	Black
Core Identification Color Code:	Red, Yellow, Blue, Black
Shape:	Round
Standard:	International Standard as required (To be mentioned).
Necessary Documents:	A catalog of the cable will be submitted with the offer.
Note:	<p>01. Sample item must be provided for approval before issuing Purchase Order or final supply of the product.</p> <p>02. There should be no core to core gap inside the cable.</p> <p>03. The cable will be used on rough surface under open sun and some parts of the cable will be laid under water.</p>